

PLACER COUNTY WATER AGENCY

Revision 1

Improvement Standards, Standard Specifications, Standard Drawings

2017 Edition

Item No.	Page No. / DWG No.	Description
1.1	24	<p>Division 2, Improvement Standards Section 1, Design Criteria for Treated Water Facilities Revise the following paragraph to read:</p> <p>Pipeline Layout and Clearances Dead-end pipelines shall be avoided wherever possible. Distribution systems shall be designed with looping pipelines such that all points within the distribution system are connected to a minimum of two source pipelines. Exceptions to this may include cul-de-sacs, at pressure zone boundaries, and at other locations approved by the Agency. In all cases, dead-ends serving greater than 20 service connections shall be avoided, except at the Agency's sole discretion, and dead-ends serving great than 40 service connections are prohibited.</p>
1.2	24	<p>Division 2, Improvement Standards Section 1, Design Criteria for Treated Water Facilities Revise the following paragraph to read:</p> <p>All crossing and separation requirements shall conform to the State of California Division of Drinking Water or the Agency's requirements, whichever is more stringent. All crossings shall be designed with the crossing being as close to perpendicular as practical and with the sewer line and laterals crossing under the water line. See Standard Drawings S103 and S104 for detailed clearance requirements.</p>
1.3	S103	Delete and replace Standard Drawing S103
1.4	S104	Delete and replace Standard Drawing S104

Dated: July 13, 2017