

# PLACER COUNTY WATER AGENCY

Revision 2

Improvement Standards, Standard Specifications, Standard Drawings

2017 Edition

Item No.	Page No. / DWG No.	Description
1.1	51	<p><b>Division 3, Standard Specifications</b>  <b>Section 1, Piping and Plumbing</b>                      Revise the following paragraph to read:</p> <p><b>Pipe Material</b>                      DIP shall conform to AWWA C151 specifications. Joints between DIP and other types of pipe shall be made by means of the properly sized and correct type of restrained adapter. DIP shall be cement mortar-lined in accordance with AWWA C104 unless otherwise noted. <b>Welded outlets may not be used.</b></p>
1.2	89	<p><b>Division 3, Standard Specifications</b>  <b>Section 6, Boring, jacking and Tunneling</b>                      Revise the following paragraph to read:</p> <p><b>Steel Pipe</b>                      Use straight-seam or spiral weld steel casing with a minimum yield stress of <b>36,000</b> psi before cold forming. Casing shall have no coating or wrapping. Machine-clean pre-wrapped casing before delivery. Maximum weld height over plate thickness shall be 3/16 inch (0.185 inch).</p>
1.3	S112	Delete and replace Standard Drawing S112
1.4	S113	Delete and replace Standard Drawing S113
1.5	S201	Delete and replace Standard Drawing S201
1.6	S202	Delete and replace Standard Drawing S202
1.7	S203	Delete and replace Standard Drawing S203
1.8	S207	Delete and replace Standard Drawing S207
1.9	S301	Delete and replace Standard Drawing S301
2.0	S304	Delete and replace Standard Drawing S304
2.1	S305	Delete and replace Standard Drawing S305
2.2	S306	Delete and replace Standard Drawing S306

Dated: June 12, 2020